



# ASPHALT TECHNOLOGIES, LLC.



## TEST & EVALUATION REPORT

May 5, 2026  
Revised June 9, 2026

**Report For:** Davlin Coatings, LLC  
700 Allston Way  
Berkeley, CA 94710

**Attn:** Mehdi Ehsani

**Email:** [mehdi@davlincoatings.com](mailto:mehdi@davlincoatings.com)

### Sample Data/Information:

| SAMPLE ID     | MATERIAL TYPE | SOURCE          | RECEIVED DATE | PRI PROJECT #      |
|---------------|---------------|-----------------|---------------|--------------------|
| 100 RR        | Rejuvenator   | Davlin Coatings | 04/10/26      | DAVL 01-02-01/02R2 |
| Aged Shingles | Shingle       | Davlin Coatings | 04/10/26      |                    |

**OBJECTIVE:** Apply two coats of as-received rejuvenator at rate of 100 square feet per gallon twice on as-received shingles. Evaluate as-received and as-treated shingles for Granular Adhesion per ASTM D4977 and Pliability per ASTM D3462.

### DATA/RESULTS:

| PROPERTIES                 | TEST METHODS | SPECIFICATIONS | RESULTS<br>CONTROL<br>SHINGLE |
|----------------------------|--------------|----------------|-------------------------------|
| <b>SAMPLE AS-RECEIVED</b>  |              |                |                               |
| <b>Select Requirements</b> |              |                |                               |
| Granule Loss, g            | D4977        | Report         | 0.52                          |
| Pliability                 | D3462        | Report         | Pass                          |

| PROPERTIES                 | TEST METHODS | SPECIFICATIONS | RESULTS<br>TREATED |
|----------------------------|--------------|----------------|--------------------|
| <b>SAMPLE AS-RECEIVED</b>  |              |                |                    |
| <b>Select Requirements</b> |              |                |                    |
| Granule Loss, g            | D4977        | Report         | 0.06               |
| Pliability                 | D3462        | Report         | Pass               |

**DISCUSSIONS:** See results in the tables above.

Tested by: John D'Angelo  
John D'Angelo, Technologist

Date: June 9, 2026

Reviewed by: Damian Jamroz  
Damian Jamroz, Client Manager

Date: June 9, 2026